

US Army Corps of Engineers  
**Washington Aqueduct Laboratory**

Lab Certification Number: DC00005

**THMs REPORT**

EPA Method 524.2

District of Columbia Water and Sewer  
Authority  
Maureen Schmelling  
Bureau of Water Services  
301 Bryant Street, NW  
Washington, DC 20001

Report Date: 10/2/2013

Report Number: LC-W1309088-001

**SAMPLE INFORMATION**

Sample Number: 1309088-001

Customer Sample Number:

Location: 1H-10 ANNE M. GODING SCHOOL, 900 F ST NE  
Type: Dist.  
DC VOC

Collection Date: 9/11/2013 Collection Time: 11:53 Sampler: LGALLIMORE Received Date and Time: 9/11/2013 3:16:27 PM Received By: LGallimore

---

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0362 mg/L	9/12/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0193 mg/L	9/12/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0071 mg/L	9/12/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	0.0005 mg/L	9/12/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.063 mg/L	9/12/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/2/2013

Date

US Army Corps of Engineers  
**Washington Aqueduct Laboratory**

Lab Certification Number: DC00005

**THMs REPORT**

EPA Method 524.2

District of Columbia Water and Sewer  
Authority  
Maureen Schmelling  
Bureau of Water Services  
301 Bryant Street, NW  
Washington, DC 20001

Report Date: 10/2/2013

Report Number: LC-W1309088-003

**SAMPLE INFORMATION**

Sample Number: 1309088-003

Customer Sample Number:

Location: 3H-4 BKJV LOWELL SCHOOL, 1640 KALMIA  
RD NW

Type: Dist.

DC VOC

Collection Date:  
9/11/2013

Collection Time:  
10:07

Sampler:  
LGALLIMORE

Received Date and Time:  
9/11/2013 3:16:27 PM

Received By:  
LGallimore

---

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0336 mg/L	9/12/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0198 mg/L	9/12/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0070 mg/L	9/12/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	9/12/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.060 mg/L	9/12/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/2/2013

Date

US Army Corps of Engineers  
**Washington Aqueduct Laboratory**

Lab Certification Number: DC00005

**THMs REPORT**

EPA Method 524.2

District of Columbia Water and Sewer  
Authority  
Maureen Schmelling  
Bureau of Water Services  
301 Bryant Street, NW  
Washington, DC 20001

Report Date: 10/2/2013

Report Number: LC-W1309088-004

**SAMPLE INFORMATION**

Sample Number: 1309088-004

Customer Sample Number:

Location: 4H-3 LAFAYETTE ELEM SCHOOL, 5701  
BROAD BRANCH ROAD NW Type: Dist.  
DC VOC

Collection Date:  
9/11/2013

Collection Time:  
9:36

Sampler:  
LGALLIMORE

Received Date and Time:  
9/11/2013 3:16:27 PM

Received By:  
LGallimore

---

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0311 mg/L	9/12/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0191 mg/L	9/12/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0074 mg/L	9/12/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	9/12/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.058 mg/L	9/12/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/2/2013

Date

**US Army Corps of Engineers**  
**Washington Aqueduct Laboratory**

Lab Certification Number: DC00005

**THMs REPORT**

EPA Method 524.2

District of Columbia Water and Sewer  
Authority  
Maureen Schmelling  
Bureau of Water Services  
301 Bryant Street, NW  
Washington, DC 20001

Report Date: 10/2/2013

Report Number: LC-W1309088-005

**SAMPLE INFORMATION**

Sample Number: 1309088-005

Customer Sample Number:

Location: A1H-8 MY 3 SONS BARBER SHOP, 3125  
MLK AVE SE Type: Dist.  
DC VOC

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
9/11/2013	13:16	LGALLIMORE	9/11/2013 3:16:27 PM	LGallimore

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0328 mg/L	9/12/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0185 mg/L	9/12/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0063 mg/L	9/12/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	9/12/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.058 mg/L	9/12/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/2/2013

Date

US Army Corps of Engineers  
**Washington Aqueduct Laboratory**

Lab Certification Number: DC00005

**THMs REPORT**

EPA Method 524.2

District of Columbia Water and Sewer  
Authority  
Maureen Schmelling  
Bureau of Water Services  
301 Bryant Street, NW  
Washington, DC 20001

Report Date: 10/2/2013

Report Number: LC-W1309088-007

**SAMPLE INFORMATION**

Sample Number: 1309088-007

Customer Sample Number:

Location: L-24 DBPR DEANWOOD RECREATION  
CENTER, 1350 49TH ST NE  
DC VOC

Type: Dist.

Collection Date:  
9/11/2013

Collection Time:  
12:30

Sampler:  
LGALLIMORE

Received Date and Time:  
9/11/2013 3:16:27 PM

Received By:  
LGallimore

---

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0372 mg/L	9/12/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0195 mg/L	9/12/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0069 mg/L	9/12/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	9/12/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.064 mg/L	9/12/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/2/2013

Date

US Army Corps of Engineers  
**Washington Aqueduct Laboratory**

Lab Certification Number: DC00005

**THMs REPORT**

EPA Method 524.2

District of Columbia Water and Sewer  
Authority  
Maureen Schmelling  
Bureau of Water Services  
301 Bryant Street, NW  
Washington, DC 20001

Report Date: 10/2/2013

Report Number: LC-W1309088-008

**SAMPLE INFORMATION**

Sample Number: 1309088-008

Customer Sample Number:

Location: L-12

BLUE PLAINS WASTE WATER  
TRTMT, 5000 OVERLOOK AVE S

Type: Dist.

DC VOC

Collection Date:  
9/11/2013

Collection Time:  
14:06

Sampler:  
LGALLIMORE

Received Date and Time:  
9/11/2013 3:16:27 PM

Received By:  
LGallimore

---

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0380 mg/L	9/12/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0205 mg/L	9/12/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0075 mg/L	9/12/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	9/12/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.066 mg/L	9/12/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/2/2013

Date

US Army Corps of Engineers  
**Washington Aqueduct Laboratory**

Lab Certification Number: DC00005

**THMs REPORT**

EPA Method 524.2

District of Columbia Water and Sewer  
Authority  
Maureen Schmelling  
Bureau of Water Services  
301 Bryant Street, NW  
Washington, DC 20001

Report Date: 10/2/2013

Report Number: LC-W1309088-010

**SAMPLE INFORMATION**

Sample Number: 1309088-010

Customer Sample Number:

Location: FIELD BLANK  
DC VOC

Type: SP

Collection Date:  
9/11/2013

Collection Time:  
7:55

Sampler:  
LGALLIMORE

Received Date and Time:  
9/11/2013 3:16:27 PM

Received By:  
LGallimore

---

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	ND mg/L	9/12/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	ND mg/L	9/12/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	ND mg/L	9/12/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	9/12/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	ND mg/L	9/12/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/2/2013

Date